

Date : 3rd Oct, 2025

Minutes of Pre-bid Meeting

For

M/s. Shri Sant Shiromani Maruti Maharaj Sahakari Sakhar Karkhana Ltd.,
Maulinagar, Belkund, Tal. Ausa, Dist. Latur, Maharashtra

Tender no. 2 : For installation of biodigester – 8000 m³ & CPU capacity 500 m³/day

The technical pre-bid meeting was conducted for installation of biodigester – 8000 m³ & CPU capacity 500 m³/day on 3rd October, 2025 at karkhana (SSSMMSSKL) site address.

Attendees :

M/s. SSS Maruti Maharaj SSK Ltd.	Name of the Suppliers
Shri. S. U. Bahir, Managing Director Shri. Arun Patil, Distillery Manager	M M Enviro Projects Pvt. Ltd. Ecoboard Industries Ltd.
V S I - Pune	Raj Process Equipments & System Pvt. Ltd.
Mr. Nitesh L. More, Alcohol Technologist Mr. Harish A. Pachpute, Alcohol Technologist	Universal Forces Industries Pvt. Ltd. Shri Samarth Engineering Pvt. Ltd.

The following points were discussed & concluded during the minutes of meeting for proposed distillery plant. Suppliers are further requested to refer MoM & prepare to their respective bids for the same.

A) Biogas plant (Digester Capa. 8000 m³) :

1. Design, supply, erection and mechanical & water commissioning of the plant & machinery should be completed within six months from the date of purchase order.
2. All civil and foundation work for biogas plant & CPU plant will be in supplier scope.
3. Foundation bolts & wedges for all equipments will be in the scope of supplier.
4. Anaerobic digester shall be considered CSTR type -supplier shall be design & supply as per discussed in pre-bid meeting.
5. Safety release devices should be considered as per tender specification.
6. For treated biomethanated spentwash outlet from lamella to lagoon HDPE piping should be considered.
7. Gas holding capacity should be considered approx. 350 m³
8. Biogas burning system is in karkhana scope & biogas pipeline with necessary foundation, structure, clamping & supports from gas blower header to the boiler shall be provided by the supplier.

9. Buffer storage tank will be considered RCC with rectangular shape instead of circular shape.
10. Biogas plant supplier will take necessary wiring/cabling, cable trays with supporting structure from PCC to their MCC with main power supply cable.
11. Distance from sugar mill to proposed biogas plant should be considered approx. 200 meter.
12. All contractor, skilled engineering staff, sub-venders, workers accommodation facility is in supplier scope. Karkhana will provide labour hutment area for site worker. Supplier will arrange to provide required material for labour rooms.
13. Labour quarter, site lockable store room, security to be arranged by supplier.
14. Sugar mill should provide plant layout drawing in Auto-Cad format & SBC data to all suppliers.
15. The water testing report has been given to all distillery plant suppliers for reference and for the purpose of design of water treatment plant (WTP).
16. Except above discussed & agreed points, all other specification of plant & machinery, terms & conditions of the bid will remain the same as per tender document.
17. Suppliers will also enclose "No deviation" letter along with technical offer.
18. The turnover criteria of supplier are waived off in this tender only.
19. Bid Submission - Technical & commercial bid, EMD to be submitted online on or before 10th October, 2025 upto 5 PM. Accordingly, the hard copy of bid documents shall be submitted physically in sealed envelope at Karkhana office.

B) Condensate Polishing Unit :

1. Design, supply, erection and mechanical & water commissioning of the plant & machinery should be completed within six months from the date of purchase order.
2. All civil and foundation work for biogas plant & CPU plant will be in supplier scope.
3. UF reject transfer pump should be considered.
4. Safety railing & walkway should be considered for entire CPU plant.
5. Supplier should be provided required chemical consumption & chemical cost per litre of treated water.
6. Electricity required for site fabrication will be supplied at actual cost at one point.
7. Suppliers will also enclose "No deviation" letter along with technical offer.

8. The turnover criteria of supplier are waived off in this tender only.
9. Supplier should be approved all necessary drawing of GA, layout & piping, electrical & instrumentation from consultant -VSI, Pune.

Note :

- This minute of meeting becomes the part of the tender document and has to be signed and stamped by the supplier and will be submitted along with tender documents and technical offer.

Special note:- EMD payable by only DD/RTGS.



*** MEETING WAS ENDED WITH VOTES OF THANKS ***

DI

MD